



कार्यालय नगर निगम ग्रेटर जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकोठी, टॉक रोड जयपुर-302015, राजस्थान)

क्रमांक :- एफ.31()मु.स्वा.अधि./ननिज/2023/56


दिनांक :- 14/06/23



SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE


It is certified that an inspection team headed by **Dr. Rashmi Kankaria**, **Chief Health Officer** from **Nagar Nigam Greater, Jaipur** inspected the **GYAN VIHAR SCHOOL** and found that **GYAN VIHAR SCHOOL, D-BLOCK, MALVIYA NAGAR, JAIPUR** has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State / U.T.Govt.

The Certificate is valid upto 31 March, 2024.


(**Dr. Rashmi Kankaria**)
Chief Health Officer
Nagar Nigam Greater Jaipur

To,

**THE PRINCIPAL,
GYAN VIHAR SCHOOL,
D-BLOCK, MALVIYA NAGAR, JAIPUR.**


PRINCIPAL
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, Jaipur-17


MANAGER
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar Jaipur


DIRECTOR
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, Jaipur-17


Mantri

OFFICE OF THE CHIEF CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/10686

Date: 18/1/2023

To,

The Sample was not Collected by this Laboratory

Gyan Vihar
D-Block, Malviya Nagar
Jaipur

Not Valid for Water Quality Legal Cases

Date of Receipt 16-01-2023

Particulars			RO Gyan Vihar D-Block, Malviya Nagar Jaipur
	value as per LS.:10500/2012		
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			16-01-2023
Lab. Sample No.			P - 103
1. pH	6.5-8.5	6.5-8.5	7.40
2. Turbidity (NTU)	1	5	NIL
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O.
5. Total Alkalinity(as CaCO ₃) mg/l	200	600	30
6. Total Hardness (as CaCO ₃) mg/l	200	600	50
7. Calcium (as Ca) mg/l	75	200	6
8. Magnesium (as Mg) mg/l	30	100	8
9. Chloride (as Cl-) mg/l	250	1000	20
10. Nitrates (as NO ₃ -) mg/l	45	45	19
11. Sulphate (as SO ₄ -2) mg/l	200	400	8
12. Total Dissolved Solids mg/l	500	2000	126
13. Fluoride mg/l	1.00	1.5	0.17
14. Iron mg/l	1.0	No Relaxation	NIL
15. Arsenic mg/l	0.01	No Relaxation	NIL

Remark- 1. All chemical parameters except pH are in mg/L
2. Tested Results Relate only to The Samples send by you

17/1/2023

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/

Date:

Copy to:-

1. The Chief Chemist, PHED Raj. Jaipur

[Signature]

PRINCIPAL
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, Jaipur-17

[Signature]
MANAGER
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, Jaipur

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

[Signature]

DIRECTOR
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, Jaipur-17

[Signature]
Shriya Sadawart Samiti



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: Lab/Bact/2022-23/ 10680

Dated: 18/01/2023

To
The Principal,
Gyan Vihar Sr. Sec. School,
D-Block, Malviya Nagar,
Jaipur, Rajasthan-302017

- Not valid for Water Quality Legal Cases.
- The Sample was not collected by this laboratory.

Reference - Your Application on dated 06.01.2023
GRN NO. - 70017824 Paid on Date 06.01.2023

Distt: Jaipur
Tehsil: Jaipur
Name of Sample Taker - Sh. Pradeep Sharma

Sample No.	Date of Collection	Date of Examination	Residual Chlorine mg/l	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:69 3829	16.01.2023	16.01.2023	—	Malviya Nagar, Jaipur	RO Water, Gyan Vihar Sr. Sec. School, D-Block, Malviya Nagar, Jaipur	Nil	Nil	Satisfactory

[Signature]
18/1/2023

Superintending Chemist
PHED, Laboratory, Jaipur
Dated:

No: Lab/Bact/2022-23/
Copy to:
1. The Chief Chemist, PHED, Rajasthan, Jaipur

~~Superintending Chemist
PHED, Laboratory, Jaipur~~

[Signature]
PRINCIPAL
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, Jaipur-17

[Signature]
MANAGER
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, Jaipur

[Signature]
DIRECTOR
GYAN VIHAR SCHOOL
D-Block, Malviya Nagar, JAIPUR-17

[Signature]
Samiti

Mantri